

**RAVENCLIFF-MCGRAWS-SAULSVILLE PUBLIC SERVICE DISTRICT  
WYOMING COUNTY, WEST VIRGINIA**

**PROPOSED  
CONTRACT #1 – NEW RICHMOND WATER LINE**

**OCTOBER 24, 2018  
ADDENDUM #2**

To whom it may concern:

**A. BOILER PLATE**

1. The Bid opening will be held November 8<sup>th</sup>, 2018 at Wyoming County Commission Office located at 155 Park Street, Pineville, Wyoming County, West Virginia, at 10:00 AM.

**B. SPECIFICATIONS**

1. **DISREGARD** previous copies of the detailed specifications in their entirety and **REPLACE** with the attached detailed specifications sealed on October 23<sup>rd</sup>, 2018.

**C. DRAWINGS**

1. **NOT APPLICABLE**

**D. QUESTIONS AND CLARIFICATIONS**

1. Question:

Is the last day for questions Monday, October 29<sup>th</sup> or Tuesday, October 30<sup>th</sup>?

Answer:

The Last Day for Questions will be end of business Tuesday, October 30, 2018 – Addendum will be overnighted to all planholders on Thursday, November 1, 2018.

2. Question:

Can automatic traffic lights be used as traffic control in place of flaggers on this project?

Answer:

The West Virginia Department of Highways will allow the use of automatic traffic lights if the equipment is approved and the sight distance allows for safe use.

**E. GENERAL**

1. A current State of West Virginia Contractor's License is required to bid the project.
2. The Engineer's Estimate is approximately \$1,500,000.

If you have any questions or need any other information, please contact Davis Altizer, P.E. via email ([baltizer@thethrasherroup.com](mailto:baltizer@thethrasherroup.com)) or by phone at 304-431-7800.

Sincerely,

THE THRASHER GROUP, INC.



David Altizer, P.E.  
Project Manager

Enclosures

