

PRESTON COUNTY BOARD OF EDUCATION
KINGWOOD, WEST VIRGINIA
PRESTON HIGH SCHOOL
HVAC UPGRADES

ADDENDUM #3

March 29, 2021
THRASHER PROJECT #101-060-10138

TO WHOM IT MAY CONCERN:

The following are clarifications and responses to questions posed by contractors for the above reference project.

A. GENERAL

Not Applicable.

B. SPECIFICATIONS

Not Applicable.

C. DRAWINGS

Not Applicable.

D. QUESTIONS AND RESPONSES

Not Applicable.

E. CLARIFICATIONS

1. Refer to Addendum No. 2 – D. Questions / Responses: REVISE the response to Question #14 as follows:

QUESTION #14: Are we reusing the existing control valves on the Unit Ventilators?

REPOSENSE: Existing control valves on Unit Ventilators shall be replaced with new.

If you have any questions, please feel free to contact me at kqblackwood@thethrashergroup.com. As a reminder, bids will be received until 11:00 am on March 31, 2021 at Preston County Schools BOE Offices in Kingwood, WV. Good luck to everyone and thank you for your interest in the project.

Sincerely,

THE THRASHER GROUP, INC.



Kenton Blackwood
Project Manager