

**CITY OF CLARKSBURG
HARRISON COUNTY, WEST VIRGINIA
BRICKSIDE BAR & GRILL DRAINAGE / SLIP REPAIR**

ADDENDUM #2

APRIL 25, 2022

THRASHER PROJECT #030-10418

TO WHOM IT MAY CONCERN:

The following are clarifications and responses to questions posed by contractors for the above reference project.

A. GENERAL

None on this Addendum

B. SPECIFICATIONS

None on this Addendum

C. DRAWINGS

None on this Addendum

D. QUESTIONS AND RESPONSES

QUESTION

1. What size stone is to be used in the grouted rock weir and outlet and how thick does the rock need to be?

RESPONSE

The rock should be a $D_{50} = 9''$ in an 18'' thick layer.

E. CLARIFICATIONS

1. On the revised bid from the quantity for item #10 Rock Weir and Outlet Control Basin shall be by the lump sum unit bid price and the quantity should read (1). A new bid form will not be reissued, so please use a single lump sum bid price for item #10.

If you have any questions or comments, please feel free to contact me at your earliest convenience. As a reminder, bids will be received until 2:00 p.m. on Thursday, April 28, 2022 at City of Clarksburg, 222 W. Main Street, Clarksburg, WV 26301. Good luck to everyone and thank you for your interest in the project.

Sincerely,

THE THRASHER GROUP, INC.



JEFF GOLLA, PE
Project Manager

