



COMPLEX PROJECTS  
REQUIRE RESOLVE  
**THRASHER'S GOT IT**

**MASON COUNTY PUBLIC SERVICE DISTRICT  
MASON COUNTY, WEST VIRGINIA**

**ASHTON WATER TREATMENT PLANT IMPROVEMENTS PROJECT**

**ADDENDUM #3**

**JULY 19, 2022**

**THRASHER PROJECT #010-10214**

TO WHOM IT MAY CONCERN:

The following are clarifications for the above reference project.

**A. GENERAL**

1. Bids will be received until 2:00 p.m. on Tuesday, July 26, 2022, at the Mason County Public Service District located at 101 Camden Avenue, Point Pleasant, Mason County, West Virginia. At that time, the Bids received will be publicly opened and read.

**B. SPECIFICATIONS**

N/A.

**C. DRAWINGS**

N/A.

**D. QUESTIONS AND RESPONSES**

N/A.

**E. CLARIFICATIONS**

1. The existing air header piping is 3" I.D. and the existing air lateral piping is ¾" I.D. in the existing filters.

If you have any questions or comments, please feel free to contact us at your earliest convenience. Good luck to everyone and thank you for your interest in the project.

Sincerely,

THE THRASHER GROUP, INC.

