

**PRESTON-TAYLOR COMMUNITY HEALTH CENTERS, INC.  
TAYLOR COUNTY, WEST VIRGINIA**

**EGLON CLINIC ADDITION  
MOUNTAIN TOP CLINIC RENOVATIONS  
ROWLESBURG CLINIC RENOVATIONS**

**ADDENDUM #2**

**OCTOBER 27, 2022**

**THRASHER PROJECT #060-10297**

TO WHOM IT MAY CONCERN:

A Pre-Bid Conference was held on Tuesday, October 18, 2022. The following are clarifications and responses to questions posed by contractors for the above reference projects.

**A. GENERAL**

**The Bid Date has been extended to Wednesday, November 9, 2022, 2:00 pm,** with delivery to Thrasher Office Building and private opening to be the same as originally specified.

**B. SPECIFICATIONS**

None on this Addendum.

**C. DRAWINGS**

None on this Addendum.

**D. QUESTIONS AND RESPONSES**

**Q1.** A generator option was mentioned at the Eglon site. Is this something that needs priced? If so, diesel models are at least doubled in price over an LP type due to the engine being liquid cooled.

**A1.** A generator will not be required for this Bid for Eglon or the other sites.

**Q2.** When the electrical service gets moved did they want a price for an underground service?

**A2.** An Add Alternate price for underground electric and communications services will be added to the Bid Form. A Revised Bid Form will be issued in a subsequent Addendum.

**Q3.** Please provide the company contact information, that maintains the automatic sprinkler and fire alarm systems.

**A3.** This has not been confirmed.

**Q4.** What size diffusers/grilles are wanted for each clinic?

**A4.** The requirement at each facility is to match existing (re-use whenever possible). Eglon and Rowlesburg Clinics will have prefinished metal floor and wall registers, probably 4x12 or 6x12 but this needs to be confirmed on site. Mountaintop will have commercial 2x2 layin grilles and diffusers.

**Q5.** For the new Data drops at Eglon is CAT6E an acceptable cable?

**A5.** The new data drops must be compatible with the existing Eglon system. If CAT6E is confirmed as equal or better it is acceptable.

## **E. CLARIFICATIONS**

None on this Addendum.

If you have any questions or comments, please feel free to contact me. As a reminder, bids will be received until 2:00 p.m. on Wednesday, November 9, 2022 at The Thrasher Group Building Reception Desk, located at 600 White Oaks Blvd, Bridgeport WV 26330. Good luck to everyone and thank you for your interest in the project.

Sincerely,

THE THRASHER GROUP, INC.



Marsha Benson  
Project Manager