

**HARRISON HILLS CITY SCHOOL DISTRICT
HARRISON COUNTY, OHIO
HARRISON HILLS CITY SCHOOL DISTRICT OUTDOOR CLASSROOM**

**ADDENDUM #3
November 18, 2022**

THRASHER PROJECT #030-10454

TO WHOM IT MAY CONCERN:

This Addendum forms a part of the Contract Documents and modifies the original Bidding Documents issued October 2022 and any subsequent addenda. Acknowledge receipt of this Addendum in the space provided on the Bid Form. Failure to do so may subject the Bidder to disqualification.

A. **GENERAL**
N/A

B. **SPECIFICATIONS**
None on this Addendum.

C. **DRAWINGS**
None on this Addendum

D. **QUESTIONS AND RESPONSES**

1. QUESTION

Detail 10/S500 shows the slab on grade on top of the wall retaining wall. But detail 2/A5.01 shows the slab on grade adjacent to the wall. Which detail is correct?

RESPONSE

The S sheets will take precedence for structural design elements. Detail 10/S500 is the preferred construction method.

2. QUESTION

Sheet S101 calls out the back wall as '8" CMU (2500 PSI) w/ #4 @16" O.C.'. But detail 1/A5.01 shows a CIP concrete wall. Which is correct?

RESPONSE

The S sheets will take precedence for structural design elements.

E. CLARIFICATIONS
None on this Addendum

If you have any questions or comments, please feel free to contact me at your earliest convenience. As a reminder, bids will be received until 1:30 p.m. on Tuesday, November 22, 2022, at Harrison Hills City School District, 100 Huskies Way, Cadiz, OH. Good luck to everyone and thank you for your interest in the project.

Sincerely,

THE THRASHER GROUP, INC.



MARCUS CARNEGIE, PLA
Project Manager

