



COMPLEX PROJECTS
REQUIRE RESOLVE
THRASHER'S GOT IT

**CANTON TOWNSHIP
STARK COUNTY, OHIO**

TOWNSHIP GARAGE AND HALL SANITARY SEWER PUMP STATION

ADDENDUM #1

FEBRUARY 6, 2023

THRASHER PROJECT #101-020-10157

TO WHOM IT MAY CONCERN:

The following is a modification and response to a question posed by contractors for the above-referenced project.

- A. **GENERAL** - None
- B. **SPECIFICATIONS** - None
- C. **DRAWINGS** - None
- D. **QUESTIONS AND RESPONSES**

QUESTION 1:

Can bidders propose an alternative method of horizontal direction drilling other than the method shown on Sheet 9?

RESPONSE:

Bidders may propose alternative methods of trenchless construction as described in Note 1 on Sheet 9 of the drawings and as described in Section 10.02 of the Instructions to Bidders for Construction Contract. The Engineer will consider any method that will result in safe installation of the force main in compliance with applicable codes and standards. Steel casing is not a required component of an alternative method.

- E. **CLARIFICATIONS** - None

If you have any questions or comments, please feel free to contact me at your earliest convenience. As a reminder, bids will be received until 12:00 p.m. on February 21, 2023, at the Canton Township Administrative Offices located at 4711 Central Avenue SE, Canton OH, 44707. Good luck to everyone and thank you for your interest in the project.

Sincerely,

THE THRASHER GROUP, INC.



Project Manager

