

**CITY OF CLARKSBURG
HARRISON COUNTY, WEST VIRGINIA
LIBERTY AVE. SLIP REPAIR**

ADDENDUM #1

MARCH 31, 2023

THRASHER PROJECT #T30-11184

TO WHOM IT MAY CONCERN:

A Pre-Bid Conference was held on Tuesday, March 28, 2023, for the Liberty Ave. Slip Repair project. A copy of the Pre-Bid sign in sheet is included in this Addendum. The following are clarifications and responses to questions posed by contractors for the above reference project.

A. GENERAL

1. **THE BID OPENING HAS BEEN EXTENDED TO THURSDAY, APRIL 13, 2023, AT 11:00 AM.**

2. An additional pile/lagging wall be added to this project. The proposed wall is for the repair of a slip along Winding Road in Clarksburg, WV. The location of the slip is approximately 350 feet up from the intersection of Winding Road with Duncan Ave. N39°17'01.60", W80°21'32.80". The wall will be approximately 90 LF long and will have the same pile size and depth, lagging size and spacing as the proposed walls on Liberty Ave. There is overhead utility directly over our proposed wall location. Therefore, contractor shall assume the lines will be temporarily/permanently relocated prior to them installing the wall.

3. A revised Bid form will be issued in an Addendum #2.

B. SPECIFICATIONS

N/A

C. DRAWINGS

N/A

D. QUESTIONS AND RESPONSES

QUESTION

1. Will Liberty Ave be able to be closed for thru traffic in slip areas until construction is completed or will be for work?

RESPONSE

Only during work hours, one lane shall be opened up for thru traffic when construction is not occurring. Contractor shall provide access for emergency for all times.

QUESTION

2. Will equipment be allowed to be left on the road in the slip area until the construction is completed?

RESPONSE

Yes, as long as there is at least one lane open during non-construction periods.

QUESTION

3. Is there a designated area for equipment and material storage near the slip area?

RESPONSE

No.

QUESTION

4. Are there any drainage pipes that will interfere with the pile wall?

RESPONSE

Yes, the plan and bid form will be updated to show installation of new inlet and rerouting of an existing storm pipe. The updates will be included in Addendum #2.

QUESTION

5. Is this project Prevailing Wages?

RESPONSE

No.

QUESTION

6. Is there an engineer's estimate?

RESPONSE

No.


E. CLARIFICATIONS

1. Contractor shall be responsible for all necessary licensing (local, state, etc.), city B&O tax, and building permit with the City.

If you have any questions or comments, please feel free to contact me at your earliest convenience. As a reminder, bids will be received until **11:00 a.m. on Thursday, April 13, 2023**, at the **222 W. Main Street, Clarksburg, WV 26301**. Good luck to everyone and thank you for your interest in the project.

Sincerely,

THE THRASHER GROUP, INC.


Jeff Gola, P.E.
Project Manager



**CITY OF CLARKSBURG
HARRISON COUNTY, WEST VIRGINIA
LIBERTY AVENUE SLIP REPAIR**

**PRE-BID CONFERENCE
Tuesday, March 28, 2023 @ 10:00 a.m.**

Thrasher Project #T30-11184

Name	Representing	Phone #	Email Address
Ron Shriver	Litman Excavating	304 672 5636	Rshriver@litmanexcavating.com
Ron Haymond	Doss Enterprises	304-627-8324	Ron.Haymond@dossenterprises.com
Brian Vandevender	Brian Vandevender Contracting	304-698-7105	briandvcontracting@gmail.com
Dakota Hinterer	RDR US6	443-789-0987	dhinterer@rdrasg.com
JEREMY WHITE	ALAN STONE COMPANY	304-580-6011	ESTIMATOR@ALANSTONECOMPANY.COM
Steve Calvert	Green River Group, LLC	304-288-1817	SCalvert@greenrivergroupllc.com
Rich Smathers	OWV EXCAVATING	740-238-3921	RSMATHERS@OWVEXCAVATING.COM
JIM GRAHAM	OWV EXCAVATING	740-312-2611	JGRAHAM@OWVEXCAVATING.COM
JAMES ALLEN	J&J ENTERPRISES	304 641 8224	JFALLEN-FARM@GMAIL.COM

Name	Representing	Phone #	Email Address
Jeff Gols	Thrasher		
H. Tom Brown	City of Clarksburg	304 624 1607	tbrown@cityofclarksburg.wv.gov