



COMPLEX PROJECTS
REQUIRE RESOLVE
THRASHER'S GOT IT

**PEA RIDGE PUBLIC SERVICE DISTRICT
CABELL COUNTY, WEST VIRGINIA**

CONTRACT #9 – LIFT STATION PUMPS & CONTROLS (VENDOR BID)

ADDENDUM #3

JULY 27, 2023

THRASHER PROJECT #020-1392

TO WHOM IT MAY CONCERN:

The following are clarifications and responses to questions posed by contractors for the above reference project.

A. GENERAL

NOT APPLICABLE

B. SPECIFICATIONS

1. Section 333213 – Paragraph 1.4.B – **ADD** the following at the end of the paragraph:
 3. The vendor shall provide detailed shop drawings of each complete pump station to the Engineer and the Contract 8 Contractor.
2. Section 333213 – Paragraph 2.1.A – **ADD** the following to the end of the paragraph:
 3. The vendor shall provide pump bases, intermediate brackets, and upper guide rail brackets for each pump specified.
3. Section 333213 – Paragraph 2.4.A.3 – **ADD** the following to the end of the paragraph:
 - c. Barnes.
4. Section 333213 – Paragraph 3.3.E – **DELETE**.
5. Section 333213 – Paragraph 3.3 – **CHANGE** to read as follows:
 - F. Manufacturer Services: The pump vendor shall provide the services of a manufacturer's representative experienced in the installation of products furnished under this section for inspection of the installation performed by the Contract 8 Contractor, startup, field testing, and instructing Owner's personnel in maintenance of equipment.

6. Section 333217 – Paragraph 1.6.A – **ADD** the following to the end of the paragraph:

2. The vendor shall provide detailed shop drawings of each complete pump station to the Engineer and the Contract 8 Contractor.

7. Section 333217 – Paragraph 2.2 – **ADD** the following at the end of the section:

- I. The vendor shall provide pump bases, intermediate brackets, and upper guide rail brackets for each pump specified.

8. Section 333217 - Paragraph 3.4.C – **CHANGE** to read as follows:

1. The vendor shall furnish the services of a manufacturer’s representative experienced in the installation of products furnished under this section for inspection of the installation of all pumps performed by the Contract 8 Contractor, startup, field testing, and instructing Owner’s personnel in maintenance of equipment.

9. Section 333217 – Paragraph 3.4.D - **DELETE**

C. DRAWINGS

NOT APPLICABLE

D. QUESTIONS AND RESPONSES

NOT APPLICABLE

E. CLARIFICATIONS

NOT APPLICABLE

If you have any questions or comments, please feel free to contact me at your earliest convenience. As a reminder, bids will be received until 2:00 p.m. on Thursday, August 3, 2023 at Pea Ridge Public Service District located at 500 Nova Street, Huntington, WV 25705. Good luck to everyone and thank you for your interest in the project.

Sincerely,

THE JONATHAN CARPENTER GROUP, INC.

Jonathan Carpenter
Principal

