



COMPLEX PROJECTS  
REQUIRE RESOLVE  
THRASHER'S GOT IT

**MASON COUNTY PUBLIC SERVICE DISTRICT  
MASON COUNTY, WEST VIRGINIA**

**CONTRACT #6 – APPLE GROVE WASTEWATER TREATMENT PLANT SBR  
EQUIPMENT (VENDOR BID)**

**ADDENDUM #2**

**JUNE 30, 2023**

**THRASHER PROJECT #020-01631**

TO WHOM IT MAY CONCERN:

Bid Opening for the above referenced project will be held on **Tuesday, July 11, 2023 at 2:00 pm**. The following are clarifications and responses to questions posed by Vendors for the above referenced project.

**A. SPECIFICATIONS**

1. NOT APPLICABLE

**B. DRAWINGS**

1. NOT APPLICABLE

**C. QUESTIONS AND RESPONSES**

**1. QUESTION**

Will there be any additional addenda for this project?

**RESPONSE**

No.

**2. QUESTION**

After review of the drawings, there is a question regarding the telescoping valve. The specs detail a 3” telescoping valve while the drawings show 4”. Which is correct?

**RESPONSE**

A 3-inch telescoping valve will be provided along with a 3-inch reducer to connect the valve to the 4-inch discharge piping.

**3. QUESTION**

AASI acknowledges that the bid requires hard copies to be sent. Will the package be transmitted directly via mail?

**RESPONSE**

Yes.

If you have any questions or comments, please feel free to contact me at your earliest convenience. As a reminder, bids will be received until 2:00 p.m. on Tuesday, July 11, 2023 at the Thrasher Group, Inc., located at 1000 Corporate Landing, Charleston, WV. Good luck to everyone and thank you for your interest in the project.

Sincerely,

THE THRASHER GROUP, INC.

  
15425  
JONATHAN CARPENTER, P.E.  
Principal  
