

VILLAGE OF MIDVALE
TUSCARAWAS COUNTY, OHIO

CONTRACT 2 – VERNON RD. & BEAN ALLEY WATER LINES

ADDENDUM #2

February 21, 2024

THRASHER PROJECT #T10-11063



TO WHOM IT MAY CONCERN:

The following are clarifications and responses to questions posed by contractors for the above-referenced project.

A. GENERAL

1. THE BID FORM HAS BEEN REVISED. YOU MUST USE THE REVISED BID FORM WHEN PREPARING YOUR BID PACKAGE FOR THIS PROJECT. (REFER TO QUESTION 1 BELOW.)

B. QUESTIONS AND RESPONSES

QUESTION

1. Bid Item #9: 8-inch HDPE-H.D.D. It shows 6-inch on the plans. Do you want 6-inch HDPE or 8-inch to be drilled?

RESPONSE

6" HDPE installed using H.D.D. **(PLEASE REPLACE C-410, PAGE 3 OF THE BID FORM.)**

QUESTION

2. Bid Item #13: Please clarify ¾ inch water services. 16 EA is called out on the bid item schedule, but only a handful are shown on the plans. Does the owner want 16 EA per detail provided, or are the plan correct, and there was a typo on the bid form?

RESPONSE

All existing service lines are to be replaced at every service connection on Bean Alley and Vernon Street, which are estimated to be 16 services in total. Service line locations are shown on the Drawings based on available information, but the precise number and location of service lines will be determined by the Contractor during construction.

C. CLARIFICATIONS

1. Please clarify what size and material the existing main is that we are to abandon.

RESPONSE

The existing mains are 6-inch cast iron.

2. Please clarify if we are to abandon the existing main with grout, or if it is an in-place abandonment.

RESPONSE

Sheet PN1 states to abandon in place by grouting the existing water line.

3. Maintenance of Traffic – the reading notes in the plans looks like we are allowed to close Bean Alley to local traffic throughout the day. Please clarify how long an acceptable duration of closure is for the project.

RESPONSE

The Village shall approve all traffic closures. The Village anticipates that the road is to be opened at the end of each workday, limiting road closures within the hours of 8:00 am and 4:00 pm. Coordination with local residents will be necessary. See sheet PN1.

If you have any questions or comments, please feel free to contact me at your earliest convenience at gdavis@thethrashergroup.com. As a reminder, bids will be received until 2:00 p.m. on Tuesday, February 27, 2024, at The Thrasher Group, 400 3rd St SE, Suite 309, Canton, OH 44702. Good luck to everyone and thank you for your interest in the project.

Sincerely,
THE THRASHER GROUP, INC.



Glenn Davis, PE, CFM
Project Manager

| BASE BID | | | | | | | |
|----------|---------|-------|--|-------|------|-----------|------|
| Item # | ODOT # | | DESCRIPTION | QTY. | UNIT | UNIT COST | COST |
| 5 | 254 | 01000 | PAVEMENT PLANING, ASPHALT CONCRETE 2-INCH | 2,151 | SY | | |
| 6 | 407 | 20000 | NON-TRACKING TACK COAT | 183 | GAL | | |
| 7 | 441 | 50000 | ASPHALT CONCRETE SURFACE COURSE, TYPE 1 | 120 | CY | | |
| 8 | 638 | 10480 | FIRE HYDRANT REMOVED | 4 | EA | | |
| 9 | SPECIAL | | 6-INCH HDPE WATER MAIN INSTALLED WITH HDD | 100 | FT | | |
| 10 | 638 | 01130 | 6-INCH PVC WATER MAIN | 1,600 | FT | | |
| 11 | 638 | 07480 | 6-INCH GATE VALVE | 8 | EA | | |
| 12 | 638 | 10200 | FIRE HYDRANT ASSEMBLY | 4 | EA | | |
| 13 | 638 | 20892 | ¾-INCH WATER SERVICE | 16 | EA | | |
| 14 | SPECIAL | | LANDSCAPING | 1 | LS | | |

TOTAL BID ACTIVITY (GENERAL) _____

NOTE: THE CONTRACTOR'S UNIT PRICES SHALL INCLUDE PURCHASE AND INSTALLATION, COMPLETE IN PLACE, PER BID ITEM IN ACCORDANCE WITH THE DETAILED SPECIFICATIONS.

Bidder acknowledges that (1) each Bid Unit Price includes an amount considered by Bidder to be adequate to cover Contractor's overhead and profit for each separately identified item, and (2) estimated quantities are not guaranteed, and are solely for the purpose of comparison of Bids, and final payment for all unit price Bid items will be based on actual quantities, determined as provided in the Contract Documents.

3.04 *Method of Award*

Method of Award = Lowest Qualified Bidder (Regular)

If at the time this contract is to be awarded, the lowest total bid submitted by a qualified, responsive, responsible Bidder does not exceed the amount of funds then estimated by the Owner, as available to finance the contract, the construction contract will be awarded. If such bids exceeds such amount, the owner may reject all bids.