



COMPLEX PROJECTS
REQUIRE RESOLVE
THRASHER'S GOT IT

**BENEDUM AIRPORT AUTHORITY
HARRISON COUNTY, WEST VIRGINIA
REHAB RUNWAY 3-21 LIGHTS, SIGNS AND UPGRADE VAULT**

**ADDENDUM #2
MAY 22, 2025**

THRASHER PROJECT # T80-11373

TO WHOM IT MAY CONCERN:

A Pre-Bid Conference was held on Wednesday, May 14, 2025, on the above-referenced project. The following are clarifications and responses to questions posed by contractors for the above-referenced project.

A. GENERAL

B. DRAWINGS

The following drawings have been revised:
E3.07 – Electrical Layout

C. QUESTIONS AND RESPONSES

1. QUESTION

Am I missing the control cables or they not there? For the L-821

RESPONSE

The specification specifies that the contractor is to install control cable as required by the L-821 manufacturer, but to use a 25PR#19SH cable for bidding purposes. This should be incidental to the control panel bid item.

2. QUESTION

Does the airport have the lighted X's or does the contractor need to supply them?

RESPONSE

Yes, the Airport will supply, mobilize and maintain the lighted X's for runway closure each night that the runway will be closed.

If you have any questions or comments, please feel free to contact me at your earliest convenience. As a reminder, bids will be received until **2:00 p.m. on Thursday, May 29, 2025**, at Benedum Airport Authority, 2000 Aviation Way, Bridgeport, WV. Good luck to everyone and thank you for your interest in the project.

Sincerely,

THE THRASHER GROUP, INC.


NICOLE JONES, PE, PMP
Project Manager



COPYRIGHT © 2025
THE THRASHER GROUP, INC.

100

[illegible]

**REHAB RUNWAY 3-21 LIGHTS, SIGNS
AND UPGRADE VAULT**

NORTH CENTRAL WEST VIRGINIA AIRPORT
2000 AVIATION WAY BRIDGEPORT, WV 26330

ISSUE PROJECT DATE
PROJECT STATS

DRAWN: DATE:
CHECKED: DATE:
APPROVED: DATE:

PROJECT No. _____

T80-11373

SHEET No. _____

E-3.07

ELECTRICAL LAYOUT

